



GREATER VISAKHAPATNAM MUNICIPAL CORPORATION
FIRE PREVENTION WING

From,
The Commissioner,
Greater Visakhapatnam
Municipal Corporation
Visakhapatnam.

To,
The District Educational Officer,
Visakhapatnam District,
Visakhapatnam.

Rc.No.00355/RFO/FPW/GVMC/2022, Dt.26-09-2022

SUB: Greater Visakhapatnam Municipal Corporation - Fire Prevention Wing - Existing Building of **M/s.Green City EM School, Sy.No.1-1, Near Apparel Export Park, Pakeertakia Post, Vadlapudi, Visakhapatnam** - **Revised Fire No Objection Certificate for Occupancy** - Issued - Reg.

- REF:**
1. Letter Rc.No: 5041/B2/97 of Director General, A.P Disaster Response & Fire Services Department, Dated: 12-03-2010.
 2. Delegation orders of the Commissioner, GVMC vide Rc.No.6721/2012/TP. Sec/G1 Dt: 13-09-2019.
 3. This Office Renewal of Fire No Objection Certificate issued vide FN030220000014, Dt.17-02-2020.
 4. Application Dt:22-09-2022 of M/s.Green City EM School, Sy.No.1-1, Near Apparel Export Park Pakeertakia Post, Vadlapudi, Visakhapatnam.

It is to inform that, vide reference 3rd cited, Renewal of Fire No Objection Certificate was issued to M/s.Green City EM School, Sy.No.1-1, Near Apparel Export Park, Pakeertakia Post, Vadlapudi, Visakhapatnam.

2) Vide reference 4th cited, an application is received by this office for issuance of Revised Fire No Objection Certificate to the existing building of M/s.Green City EM School, Sy.No.1-1, Near Apparel Export Park, Vadlapudi, Pakeertakia Post, Vadlapudi, Visakhapatnam as there are additional floors constructed.

3) Therefore, the District Fire Officer and Station Fire Officer, Fire Prevention Wing, GVMC has inspected the premises of M/s.Green City EM School, Sy.No.1-1, Near Apparel Export Park, Pakeertakia Post, Vadlapudi, Visakhapatnam on 24-09-2022 and submitted the following report.

4) Particulars of the building:

(a)	Address of the building	M/s.Green City EM School, Sy.No.1-1, Near Apparel Export Park, Pakeertakia Post, Vadlapudi, Visakhapatnam.
(b)	Total Plot Area	12140.00 Sq.Mtrs.
(c)	Height of the building	14.90 Mtrs.
(d)	No. of floors	Ground + 03 Upper Floors
(e)	Type of occupancy	Educational (School)

5) The floor wise details

Sl. No.	Floor	Build up Area in Sq. Meters.	Occupancy Type
1	Ground	1346.45	Educational (School)
2	First	1229.22	Educational (School)
3	Second	1229.22	Educational (School)
4	Third	1229.22	Educational (School)
	Total	5034.11	

6) Means of Escape:

- The Management has provided Three Internal Staircases with width of 1.50 Mtrs. each from Ground floor to terrace which is sufficient for Occupant load.



Contd.p.2

:: 2 ::

7) The Minimum Fire Safety Installations required & provided by the Builder.

Sl. No.	Fire Fighting Systems	Required	Provided	Deficit
1.	Fire Extinguishers	50 Nos.	50 Nos.	Nil
2.	Manual Call Points	08 Nos.	08 Nos.	Nil
3.	Terrace Tank	10,000 Ltrs.	10,000 Ltrs.	Nil
4.	Plunger pump with 02 HP Motor	02 Nos.	02 Nos.	Nil

- 8) The management has remitted an amount of Rs.1,47,400/- vide challan No.2022-CH-08785, Dt.23-09-2022 towards fire precautionary fees.
- 9) The Fire safety systems were tested by the District Fire Officer and Station Fire Officer, Fire Prevention Wing, GVMC during the inspection and performance found satisfactory and recommended for issuance of Renewal of Fire No Objection Certificate.
- 10) Therefore, **Revised Fire No Objection Certificate** is hereby issued to the Educational Building of M/s.Green City EM School, Sy.No.1-1, Near Apparel Export Park, Pakeertakia Post, Vadlapudi, Visakhapatnam subject to the following conditions:

i.	All the protection arrangements shall be maintained in good condition as seen during inspection
ii.	All the escape / exit routes shall not be kept locked / blocked or encroached
iii.	All the occupants must know the correct method of operation of the fire fighting system installed
iv.	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.
v.	All students / staff members of the institution shall be trained to operate the fire safety equipments during Emergency.
vi.	Addition / alteration, if any in the building may be obtained with prior permission from this department.
vii.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

- 11) The **Revised of Fire No Objection Certificate** issued to M/s.Green City EM School, Sy.No.1-1, Near Apparel Export Park, Pakeertakia Post, Vadlapudi, Visakhapatnam is **valid for 5 years from 26-09-2022 to 25-09-2027** and the Management shall submit the application for Renewal of Fire No Objection Certificate two (2) months before the date of expiry.
- 12) The issuing of Fire NOC is without any prejudice to action taken by GVMC against Unauthorized Construction, if any made.

(D.Niranjan Reddy)
 26/9/2022

Regional Fire Officer
Fire Prevention Wing,
Greater Visakhapatnam Municipal Corporation,
Visakhapatnam

Copy to the Chief City Planner, GVMC, Visakhapatnam.

Copy to the Management, M/s.Green City EM School, Sy.No.1-1, Near Apparel Export Park, Pakeertakia Post, Vadlapudi, Visakhapatnam.



V. Suseela
PRINCIPAL
GREEN CITY ENGLISH MEDIUM SCHOOL
 Near Apparel Export Park, Green City
VISAKHAPATNAM-530 049, (A.P.)

For Green City English Medium School
K.V. Bhaskar
Secretary & Correspondent